

Bellingham Public Schools Action Plan : Lead in Drinking Water

School Information

School Name: Whatcom Middle School

School District: Bellingham Public Schools

County: Whatcom County

Sampling and Testing Information

School Name	Sampling Date	Date Test Results Received	Sampling and Testing Provider
-------------	---------------	----------------------------	-------------------------------

3) 10/12- 375218 WMS
13/22 Main Building
Science

11)	4/6/23	230404 21	WMS Old Building	Wood Shop Left faucet	67	Faucets bagged and water turned off temporary permanent	4/14/23
12)	4/6/23	230404- 18	WMS Old Building	Room S2	5.1	Handwashing only sign temporary permanent	4/14/23
13)	4/6/23	230404 10	WMS Main Building	217 Sink, fountain	8.1	Handwashing only sign then water shut off to fountain temporary permanent	4/14/23
14)	4/6/23	230404 14	WMS Main Building	211 Sink, fountain	12	Handwashing only sign then water shut off to fountain temporary permanent	4/14/23

Remediation Schedule

Remediation activities are short-term or permanent control measures to reduce lead concentrations in drinking water to 5 ppb or less. Per RCW 28A.210.410, outlets that have elevated lead levels (above 5 ppb) must be identified, remediated (or permanently mitigated) and retested. Refer to the [technical guidance](#) for remediation options.

Whatcom Middle School has identified 2 drinking water outlets with elevated lead levels requiring remediation. (Outlets listed in the previous table with temporary

Post-Remediation Testing

School Name	Completed Post Remediation Testing	Planned Post Remediation Testing
WMS	1 outlet has been sampled and retested	